




WATER QUALITY REPORT

Water testing performed in 2010



PWSID#: 3350745, 3351566

This report was prepared by:
City of Leesburg
223 South 5th Street
Leesburg, FL 34748

Quality First

Once again we are proud to present our annual water quality report. This edition covers all testing performed between January 1 and December 31, 2010. As in years past, we are committed to delivering the best-quality drinking water possible. To that end, we remain vigilant in meeting the challenges of new regulations, source water protection, water conservation, and community outreach and education while continuing to serve the needs of all of our water users. Thank you for allowing us to continue providing you and your family with high-quality drinking water.

We encourage you to share your thoughts with us on the information contained in this report. Should you ever have any questions or concerns, we are always available to assist you.



For more information about this report, or for any questions relating to your drinking water, please call Al Purvis, Chief Water Operator, at (352) 728-9845 or visit our Web site at www.leesburgflorida.gov.

Community Participation

You are invited to participate in our city commission meetings and voice your concerns about your drinking water. We meet on the third floor of City Hall on the second and fourth Monday of each month beginning at 5 p.m. City Hall is located at 501 W. Meadow Street in Leesburg, Florida.

Where Does My Water Come From?

Our source of supply for the City of Leesburg's Main and East water systems is groundwater taken from the Floridan Aquifer within the Oklawaha Watershed. In both water systems, chlorine in gas form is added as a precaution against any bacteria that may be present. (We carefully monitor the amount of chlorine, adding the lowest quantity necessary to protect the safety of your water without compromising taste.)

The City of Leesburg Main Water Treatment Plant has eight deep wells ranging in depth from 250 feet to 950 feet located within the city limits. The City of Leesburg has 3.7 million gallons of storage capacity, with more than 322 miles of distribution water mains. The main water system serves 9,910 meter connections, representing an estimated population of 34,685 customers.

The East system, consisting of the Mall and Airport Water Treatment Plants, presently has two deep wells ranging in depth from 366 feet to 555 feet. The East system has 160,000 gallons of storage capacity, with more than 85 miles of distribution water mains. This system serves 2,692 meter connections representing an estimated population of 9,422 customers.

To learn about your watershed on the Internet, go to the U.S. EPA's Surf Your Watershed Web site at www.epa.gov/surf.

Important Health Information

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants may be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The U.S. EPA/CDC (Centers for Disease Control and Prevention) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791 or www.epa.gov/drink/hotline/.

Information on the Internet

The U.S. EPA Office of Water (www.epa.gov/watrhome) and the Centers for Disease Control and Prevention (www.cdc.gov) Web sites provide a substantial amount of information on many issues relating to water resources, water conservation and public health.

Substances That Could Be in Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include: Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production and can also come from gas stations, urban stormwater runoff, and septic systems; and Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U.S. EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at (800) 426-4791.

Lead and Drinking Water

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high-quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

Source Water Assessment

In 2009 the Department of Environmental Protection performed a Source Water Assessment on our system. The assessment was conducted to provide information about any potential sources of contamination in the vicinity of our wells. There are 26 potential sources of contamination identified for the City's system, with a moderate susceptibility level.

The East system has 10 potential sources of contamination, with a moderate susceptibility level. The assessment results are available on the FDEP Source Water Assessment and Protection Program Web site at www.dep.state.fl.us/swapp, or they can be obtained from the City of Leesburg Environmental Services at (352) 728-9845.

Sampling Results

During the past year we have taken hundreds of water samples in order to determine the presence of any radioactive, biological, inorganic, volatile organic, or synthetic organic contaminants. The tables below show only those contaminants that were detected in the water. Although all of the substances listed here are under the Maximum Contaminant Level (MCL), we feel it is important that you know exactly what was detected and how much of each substance was present in the water. The state allows us to monitor for certain substances less often than once per year because the concentrations of these substances do not change frequently. In these cases, the most recent sample data are included, along with the year in which the sample was taken.

PRIMARY REGULATED CONTAMINANTS

Radioactive Contaminants ¹													
CONTAMINANT AND UNIT OF MEASUREMENT	MCL VIOLATION (YES/NO)	City of Leesburg			East (Mall)			East (Airport)					
		DATE OF SAMPLING (MO./YR.)	LEVEL DETECTED	RANGE OF RESULTS	DATE OF SAMPLING (MO./YR.)	LEVEL DETECTED	RANGE OF RESULTS	DATE OF SAMPLING (MO./YR.)	LEVEL DETECTED	RANGE OF RESULTS	MCLG	MCL	LIKELY SOURCE OF CONTAMINATION
Alpha Emitters (pCi/L)	No	6/08	2.2	NA	1/08	5.0	NA	6/08	2.4	NA	0	15	Erosion of natural deposits
Radium 226 + 228 [Combined Radium] (pCi/L)	No	6/08	1.3	NA	6/08	1.0	NA	6/08	2.0	NA	0	5	Erosion of natural deposits
Inorganic Contaminants													
Barium (ppm)	No	1/08	0.0127	NA	1/08	0.009	NA	1/08	0.014	NA	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Cadmium (ppb)	No	NA	NA	NA	NA	NA	NA	1/08	0.9	NA	5	5	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints
Fluoride (ppm)	No	1/08	0.149	NA	1/08	0.16	NA	1/08	0.13	NA	4	4.0	Erosion of natural deposits; discharge from fertilizer and aluminum factories; water additive that promotes strong teeth when at optimum levels between 0.7 and 1.3 ppm
Sodium (ppm)	No	1/08	6.34	NA	1/08	5.40	NA	1/08	5.280	NA	NA	160	Salt water intrusion; leaching from soil

Stage 1 Disinfectants and Disinfection By-Products ²													
		City of Leesburg			East (Mall)			East (Airport)					
CONTAMINANT AND UNIT OF MEASUREMENT	MCL VIOLATION (YES/NO)	DATE OF SAMPLING (MO./YR.)	LEVEL DETECTED	RANGE OF RESULTS	DATE OF SAMPLING (MO./YR.)	LEVEL DETECTED	RANGE OF RESULTS	DATE OF SAMPLING (MO./YR.)	LEVEL DETECTED	RANGE OF RESULTS	MCLG OR [MRDLG]	MCL OR [MRDL]	LIKELY SOURCE OF CONTAMINATION
Chlorine (ppm)	No	1/10–12/10	1.48	1.26–1.85	1/10–12/10	1.45	1.23–1.67	1/10–12/10	1.45	1.23–1.67	[4]	[4.0]	Water additive used to control microbes
Haloacetic Acids (five) [HAA5] (ppb)	No	7/10	19.1	NA	10/08	10.6	NA	7/08	12.7	NA	NA	60	By-product of drinking water disinfection
TTHM [Total trihalomethanes] (ppb)	No	7/10	9.38	NA	10/08	19.45	NA	7/08	12.9	NA	NA	80	By-product of drinking water disinfection
Lead and Copper (Tap water samples were collected from sites throughout the community)													
		City of Leesburg			East (Mall) and East (Airport)								
CONTAMINANT AND UNIT OF MEASUREMENT	AL EXCEEDANCE (YES/NO)	DATE OF SAMPLING (MO./YR.)	90TH PERCENTILE RESULT	NO. OF SAMPLING SITES EXCEEDING THE AL	DATE OF SAMPLING (MO./YR.)	90TH PERCENTILE RESULT	NO. OF SAMPLING SITES EXCEEDING THE AL		MCLG	AL (ACTION LEVEL)	LIKELY SOURCE OF CONTAMINATION		
Copper [tap water] (ppm)	No	7/08	0.936	0	7/08	0.885	0		1.3	1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives		
Lead [tap water] (ppb)	No	7/08	4.9	0	7/08	3.8	0		0	15	Corrosion of household plumbing systems; erosion of natural deposits		
UNREGULATED SUBSTANCES (CITY OF LEESBURG) ³													
CONTAMINANT AND UNIT OF MEASUREMENT		DATE OF SAMPLING (MO./YR.)	AVERAGE RESULT	RANGE OF RESULTS	LIKELY SOURCE OF CONTAMINATION								
1,2,4-Trimethyl-5-nitrobenzene (S)		3/1/10	85 %	70 %–130 %	NA								
1,3,5-Trimethyl-2-nitrobenzene (S)		3/1/10	81 %	70 %–130 %	NA								
1,3-Dimethyl-2-nitrobenzene (S)		3/1/10	87 %	70 %–130 %	NA								
Nitrobenzene–d5 (S)		3/1/10	87 %	70 %–130 %	NA								
Perylene–d12 (S)		3/1/10	83 %	70 %–130 %	NA								
Triphenyln phosphate (S)		3/1/10	109 %	70 %–130 %	NA								

¹Results in the Level Detected column for radioactive contaminants and inorganic contaminants are the highest average at any of the sampling points or the highest detected level at any sampling point, depending on the sampling frequency.

²For chlorine, the level detected is the the highest running annual average (RAA), computed quarterly, of monthly averages of all samples collected. For haloacetic acids or TTHM, the level detected is the highest RAA, computed quarterly, of quarterly averages of all samples collected if the system is monitoring quarterly or is the average of all samples taken during the year if the system monitors less frequently than quarterly. Range of Results is the range of individual sample results (lowest to highest) for all monitoring locations, including Initial Distribution System Evaluation (IDSE) results as well as Stage 1 compliance results.

³We have been monitoring for unregulated contaminants (UCs) as part of a study to help the U.S. Environmental Protection Agency (U.S. EPA) determine the occurrence in drinking water of UCs and whether or not these contaminants need to be regulated. At present, no health standards (for example, maximum contaminant levels) have been established for UCs. However, we are required to publish the analytical results of our UC monitoring in our annual water quality report. If you would like more information on the U.S. EPA's Unregulated Contaminants Monitoring Rule, please call the Safe Drinking Water Hotline at (800) 426-4791.

Definitions

AL (Action Level): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

IDSE (Initial Distribution System Evaluation): An important part of the Stage 2 Disinfection Byproducts Rule (DBPR). The IDSE is a one-time study conducted by water systems to identify distribution system locations with high concentrations of trihalomethanes (THMs) and haloacetic acids (HAAs). Water systems will use results from the IDSE, in conjunction with their Stage 1 DBPR compliance monitoring data, to select compliance monitoring locations for the Stage 2 DBPR.

MCL (Maximum Contaminant Level): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG (Maximum Contaminant Level Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MRDL (Maximum Residual Disinfectant Level): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG (Maximum Residual Disinfectant Level Goal): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

NA: Not applicable

ND (Not detected): Indicates that the substance was not found by laboratory analysis.

pCi/L (picocuries per liter): A measure of radioactivity.

ppb (parts per billion): One part substance per billion parts water (or micrograms per liter).

ppm (parts per million): One part substance per million parts water (or milligrams per liter).